

COOLING PERFORMANCE FOR MODULAR OR EXTRUDED PANELS

		SELECT COLUMN FROM ROOM CONDITIONS AND % GLASS					
		A	B	C	D	E	F
ROOM AIR TEMPERATURE MINUS MWT DEG F.	10	17	21	28	35	38	40
	11	19	23	30	37	40	42
	12	21	25	31	38	41	43
	13	22	27	33	40	43	45
	14	24	28	35	42	45	47
	15	26	30	38	44	47	48
	16	28	32	39	45	48	50
	17	30	34	41	47	50	52
	18	31	36	43	49	52	53
	19	33	38	45	50	54	55
	20	35	40	46	52	55	57
	21	37	42	48	54	57	58
	22	39	43	50	56	59	60
	23	40	45	52	58	61	62
	24	42	47	53	59	62	63
	25	44	49	55	61	64	65
	26	46	51	56	63	66	67
	27	48	53	58	64	67	68
28	49	55	60	65	69	72	

A. INTERIOR ROOM

B. NO GLASS EXTERIOR WALL IN SUN OR FULLY SHADED GLASS AND WALL

C. 25% CLEAR GLASS EXTERIOR WALL IN SUN

D. 50% CLEAR GLASS EXTERIOR WALL IN SUN

E. 75% CLEAR GLASS EXTERIOR WALL IN SUN

F. 100% CLEAR GLASS EXTERIOR WALL IN SUN